



**CONSTRUCTION DIVISION**  
 2441 Headington Road  
 Placerville CA 95667  
 Phone: (530) 642-4987  
 Fax: (530) 295-2655

**KIMBERLY A. KERR.**  
 Interim Director of  
 Transportation  
  
 Internet Web Site:  
<http://edcgov.us/dot>

**MAIN OFFICE**  
 2850 Fairlane Court  
 Placerville CA 95667  
 Phone: (530) 621-5900  
 Fax: (530) 626-0387



**DATE:** March 26, 2012  
  
**TO:** All Prospective Bidders  
  
**SUBJECT:** **Addendum No. 1**  
**Energy Retrofitting Project – South Lake Tahoe (SLT) Interior**  
**Lighting Upgrades Contract No. PW 11-30626, CIP No. 90058**

Submit proposals for this work with the understanding and full consideration of this addendum. The revisions declared in this addendum are essential parts of the Contract.

ITEM NO.	LOCATION, PAGE OR DRAWING NO.	DESCRIPTION OF CHANGE
1.01	Draft Agreement Pages C-1 & C-2	Change paragraphs A, B and C of Article 2 to read as follows:  <b>A. Department of Transportation Maintenance Yard, 1121 Shakori Drive, Lighting Upgrades</b> consists of furnishing all labor, tools, material and equipment required to retrofit the following in accordance with Article 3 of the Draft Agreement:  1. Retrofit thirty-three (33) F40T12/ES-2 lamp (Magnetic Ballast) F42EE fixtures to F32T8 (28W)-2 lamp (Electronic Ballast) F42WLL fixtures.  2. Retrofit one (1) F40T12/ES-3 lamp (Magnetic Ballast) F43EE fixture to a F32T8 (28W)-2 lamp (Electronic Ballast) F42WLL fixture.  3. Retrofit eight (8) F40T12/ES-4 lamp (Magnetic Ballast) F44EE fixtures to F32T8 (28W)-2 lamp (Electronic Ballast) F42WLL fixtures.  4. Retrofit forty-five (45) F96T12/HO/ES-2 lamp (Magnetic Ballast) F82EHS fixtures to F32T8 (28W)-4 lamp (Electronic Ballast) F44WLL fixtures (retrofit kits required).

		<p><b>B. El Dorado Center, 3368 Lake Tahoe Boulevard, Lighting Upgrades</b> consists of furnishing all labor, tools, material and equipment required to retrofit the following in accordance with Article 3 of the Draft Agreement:</p> <ol style="list-style-type: none"> <li>1. Retrofit one (1) F20T12-1 lamp (Magnetic Ballast) F21SS fixture to a F20T8-1 lamp (Electronic Ballast) F21LL fixture.</li> <li>2. Retrofit two (2) F20T12-2 lamp (Magnetic Ballast) F22EE fixtures to F20T8-2 lamp (Electronic Ballast) F22LL fixtures.</li> <li>3. Retrofit one (1) F40T12/ES-1 lamp (Magnetic Ballast) F41EE fixture to a F32T8 (28W)-1 lamp (Electronic Ballast) F41WLL fixture.</li> <li>4. Retrofit two (2) F40T12/ES-2 lamp (Magnetic Ballast) F42EE fixtures to F32T8 (28W)-2 lamp (Electronic Ballast) F42WLL fixtures.</li> <li>5. Retrofit two hundred thirty-six (236) F40T12/ES-4 lamp (Magnetic Ballast) F44EE fixtures to F32T8 (28W)-2 lamp (Electronic Ballast) F42WLL fixtures.</li> <li>6. Retrofit two (2) FUT12/ES-2 lamp (Magnetic Ballast) FU2EE fixtures to FU31T8/6 - 2 lamp (Electronic Ballast) FU21LL fixtures.</li> <li>7. Retrofit two (2) F72T12/HO-2 lamp (Magnetic Ballast) F62SHE fixtures to F32T8 (28W)-4 lamp (Electronic Ballast) F42WLL fixtures, in two sign structures on outside of building.</li> <li>8. Retrofit two (2) F96T12/HO/ES - 2 lamp (Magnetic Ballast) F84EHE fixtures to F32T8 (28W)-4 lamp (Electronic Ballast) F44WLL fixtures, in two sign structures on outside of building.</li> </ol>
--	--	--

		<p><b>C. Johnson Government Center, 1360 Johnson Boulevard, Lighting Upgrades</b> consists of furnishing all labor, tools, material and equipment required to retrofit the following in accordance with Article 3 of the Draft Agreement:</p> <ol style="list-style-type: none"> <li>1. Retrofit twenty-six (26) F40T12/ES-1 lamp (Magnetic Ballast) F41EE fixtures to F32T8 (28W)-1 lamp (Electronic Ballast) F41LL fixtures.</li> <li>2. Retrofit thirty-four (34) F40T12/ES-2 lamp (Magnetic Ballast) F42EE fixtures to F32T8 (28W)-2 lamp (Electronic Ballast) F42WLL fixtures.</li> <li>3. Retrofit three hundred nineteen (319) F40T12/ES-3 lamp (Magnetic Ballast) F43EE fixtures to F32T8 (28W)-2 lamp (Electronic Ballast) F42WLL fixtures.</li> <li>4. Retrofit ten (10) F40T12/ES-4 lamp (Magnetic Ballast) F44EE fixtures to F32T8 (28W)-2 lamp (Electronic Ballast) F42WLL fixtures.</li> <li>5. Retrofit sixty-one (61) FUT12/ES-2 lamp (Magnetic Ballast) FU2EE fixtures to FU31T8/6 - 2 lamp (Electronic Ballast) FU21LL fixtures.</li> </ol>
--	--	---

Indicate receipt of this addendum by filling in the number of this addendum in the space provided on the signature page of the proposal.


Holders who have already mailed their proposal can contact Janel Gifford at (email: [Janel.Gifford@edcgov.us](mailto:Janel.Gifford@edcgov.us)) to arrange return of their proposal.

Inform all suppliers and subcontractors as necessary.

The DOT is only sending this addendum by posting on the following website: <http://www.edcgov.us/Government/DOT/Bids.aspx>.


If you are not a Contract Documents Holder, but request a set of documents to bid on this project, you must comply with the requirements of this addendum when submitting your bid.

End of Addendum No. 1



Recommended by:  
Janel Gifford, P.E.  
Office Engineer

3/26/12  
Date



Approved by:  
Kimberly A. Kerr  
Interim Director of Transportation

3/26/12  
Date